



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-14**

**Lab# 452**

**Customer**

Facility Name: Doubletree Cranberry

Address: 910 Sheraton Dr  
Mars, PA 16046

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 7/14/26

Time: 11:28 AM

Method: Grab

**Sample Final Analysis**

Date: 7/17/26

Time: 11:00 AM

Analyst: #REF!

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/15/26              | 10:50 AM | MH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/15/26              | 10:50 AM | MH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/14/26              | 5:00 PM  | MH      | SM 9215B |

| Field Analysis | Results   | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|-----------|-----------------|-----------|----------|---------|--------|
| pH:            | 8.0 SU    | 7.2 - 7.8 SU    | 7/14/26   | 11:28 AM | EG      | DPD    |
| Chlorine:      | 10.0 mg/l | 1.0 - 5.0 mg/l  | 7/14/26   | 11:28 AM | EG      | DPD    |
| Turbidity:     | 1 NTU     | 1 - 2 NTU       | 7/14/26   | 11:28 AM | EG      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor