



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 377

Customer

Facility Name: *Drury Hotel*
Address: *745 Grant St.*
Pittsburgh, PA 15219

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *7/13/26*
Time: *12:05 PM*
Method: *Grab*

Sample Final Analysis

Date: *7/16/26*
Time: *1:00 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Escherichia Coli:	Absent	Absent	7/14/26 12:30 PM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/14/26 12:30 PM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	7/13/26 6:30 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Fecal Streptococcus	0/100mls	2/100mls	7/14/26 2:40 PM	AH	SM 9230C
---------------------	----------	----------	-----------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
-----------------------	----------------	------------------------	------------------	----------------	---------------

pH:	7.6 SU	7.2 - 7.8 SU	7/13/26 12:05 PM	JB	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/13/26 12:05 PM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/13/26 12:05 PM	JB	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)