



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 2668

Customer

Facility Name: Veteran's Memorial Park -City of Greensburg
Address: 520 New Alexandria Rd.
Greensburg, PA 15601

Sample Collection

Date: 7/13/26
Time: 9:50 AM
Method: Grab

Sample Final Analysis

Date: 7/16/26
Time: 11:00 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/14/26	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/14/26	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/13/26	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	7/13/26	9:50 AM	LL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/13/26	9:50 AM	LL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/13/26	9:50 AM	LL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor