



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 2698

Customer

Facility Name: Highland House Tower

Address: 5700 Bunkerhill St
Pittsburgh, PA 15206

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/15/26

Time: 12:05 PM

Method: Grab

Sample Final Analysis

Date: 7/18/26

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/26	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/26	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/15/26	4:27 PM	MH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/15/26	12:05 PM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/15/26	12:05 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/26	12:05 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor