



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-11**

**Lab# 445**

**Customer**

**Facility Name:** Highpoint Fitness  
**Address:** 1000 Higbee Dr.  
Bethel Park, PA 15102

**Sample Collection**

**Date:** 7/13/26  
**Time:** 2:00 PM  
**Method:** Grab

**Matrix:** Recreational Water  
**Source Type:** Spa

**Sample Final Analysis**

**Date:** 7/16/26  
**Time:** 10:30 AM  
**Analyst:** AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                       |          |          |         |          |    |          |
|-----------------------|----------|----------|---------|----------|----|----------|
| Escherichia Coli:     | Absent   | Absent   | 7/14/26 | 10:00 AM | MD | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls | 7/14/26 | 10:00 AM | MD | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml   | 7/13/26 | 5:00 PM  | AS | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                     |          |          |         |         |    |          |
|---------------------|----------|----------|---------|---------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 7/14/26 | 2:40 PM | AH | SM 9230C |
|---------------------|----------|----------|---------|---------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

|            |          |                |         |         |     |        |
|------------|----------|----------------|---------|---------|-----|--------|
| pH:        | 7.6 SU   | 7.2 - 7.8 SU   | 7/13/26 | 2:00 PM | AHV | DPD    |
| Chlorine:  | 2.0 mg/l | 1.0 - 5.0 mg/l | 7/13/26 | 2:00 PM | AHV | DPD    |
| Turbidity: | 1 NTU    | 1 - 2 NTU      | 7/13/26 | 2:00 PM | AHV | Visual |

**Sample comments**

*Andre Smith*

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)