



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 178

Customer

Facility Name: Hyatt Place
Address: 260 North Shore Dr.
Pittsburgh, PA 15212
Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 7/13/26
Time: 2:50 PM
Method: Grab

Sample Final Analysis

Date: 7/16/26
Time: 1:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/14/26	12:30 PM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/14/26	12:30 PM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	7/13/26	6:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/13/26	2:50 PM	JB	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/13/26	2:50 PM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/13/26	2:50 PM	JB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor