



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 2342

Customer

Facility Name: *McCandless Swim Club*
Address: *Red coach & Thompson Run Rd.*
McCandless, PA 15237

Sample Collection

Date: *7/13/26*
Time: *4:40 PM*
Method: *Grab*

Sample Final Analysis

Date: *7/16/26*
Time: *12:00 PM*
Analyst: *AS*

Matrix: *Recreational Water*

Source Type: *Dive Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/14/26	11:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/14/26	11:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/13/26	6:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/13/26	4:40 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/13/26	4:40 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/13/26	4:40 PM	MM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)