



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 2348

Customer

Facility Name: Meadowink Swim Club
Address: 4220 Bulltown Rd
Murrysville PA 15668

Matrix: Recreational Water
Source Type: Deep End

Sample Collection

Date: 7/14/26
Time: 2:58 PM
Method: Grab

Sample Final Analysis

Date: 7/17/26
Time: 1:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/26	1:05 PM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/26	1:05 PM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/26	6:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/14/26	2:58 PM	DW	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/14/26	2:58 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/26	2:58 PM	DW	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)