



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-12

Lab# 2488

Customer

Facility Name: Shannopin C.C.
Address: 1 Windmere Rd.
Pittsburgh, PA 15202

Sample Collection

Date: 7/13/26
Time: 9:35 AM
Method: Grab

Sample Final Analysis

Date: 7/16/26
Time: 10:00 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Splash Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/14/26	9:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/14/26	9:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/13/26	4:25 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/13/26	9:35 AM	IS	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/13/26	9:35 AM	IS	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/13/26	9:35 AM	IS	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)