



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-12**

**Lab# 2677**

**Customer**

**Facility Name:** Thomas Jeffererson H.S.

**Address:** 310 Old Clairton Rd.  
Clairton, PA 15025

**Matrix:** Recreational Water

**Source Type:** Deep End

**Sample Collection**

**Date:** 7/14/26

**Time:** 12:50 PM

**Method:** Grab

**Sample Final Analysis**

**Date:** 7/17/26

**Time:** 1:00 PM

**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/15/26 12:30 PM     | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/15/26 12:30 PM     | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/14/26 6:45 PM      | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time        | Analyst | Method |
|----------------|----------|-----------------|------------------|---------|--------|
| pH:            | 7.2 SU   | 7.2 - 7.8 SU    | 7/14/26 12:50 PM | AHV     | DPD    |
| Chlorine:      | 2.0 mg/l | 1.0 - 5.0 mg/l  | 7/14/26 12:50 PM | AHV     | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/14/26 12:50 PM | AHV     | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)