



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 349

Customer

Facility Name: Courtyard University Center

Address: 100 Lytton Ave.
Pittsburgh, PA 15213

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/14/26

Time: 12:35 PM

Method: Grab

Sample Final Analysis

Date: 7/17/26

Time: 12:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/26	11:30 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/26	11:30 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/26	6:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	7/14/26	12:35 PM	JB	DPD
Chlorine:	7.8 mg/l	1.0 - 5.0 mg/l	7/14/26	12:35 PM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/26	12:35 PM	JB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor