



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 483

Customer

Facility Name: YMCA - Schneider
Address: 2001 Ehrman Rd
Cranberry, PA 16066

Sample Collection

Date: 7/15/26
Time: 11:15 AM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Small Pool

Date: 7/18/26
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/26	9:30 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/26	9:30 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	7/15/26	4:10 PM	MH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/15/26	11:15 AM	EG	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/15/26	11:15 AM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/26	11:15 AM	EG	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)