



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2544

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Valleybrook Swim Club*

Address: *100 Callender Rd*
Pittsburgh, PA 15237

Matrix: *Recreational Water*

Source Type: *Shallow End*

Sample Collection

Date: *7/14/26*

Time: *2:35 PM*

Method: *Grab*

Sample Final Analysis

Date: *7/17/26*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/26	9:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/26	9:50 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/26	4:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/14/26	2:35 PM	IS	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	7/14/26	2:35 PM	IS	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/26	2:35 PM	IS	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor