



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 326

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Virginia Mansions*

Address: *2120 Greentree Rd*
 Pittsburgh, PA 15220

Sample Collection

Date: *7/13/26*
Time: *9:29 AM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Final Analysis

Date: *7/16/26*
Time: *12:00 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Escherichia Coli:	Absent	Absent	7/14/26	11:50 AM	MD	SM 9222G
Total coliforms:	2/100mls	2/100mls	7/14/26	11:50 AM	MD	SM 9222B
Standard plate count:	5700/ml	200/ml	7/13/26	6:00 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Fecal Streptococcus	0/100mls	2/100mls	7/14/26	2:40 PM	AH	SM 9230C
---------------------	----------	----------	---------	---------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
-----------------------	----------------	------------------------	------------------	----------------	---------------

pH:	7.2 SU	7.2 - 7.8 SU	7/13/26	9:29 AM	SL	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/13/26	9:29 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/13/26	9:29 AM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)