



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2773

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Belmont Park

Date: 7/13/26

Time: 3:45 PM

Address: 2003 Sabino Dr
Washington, PA 15301

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 7/16/26

Time: 11:30 AM

Source Type: Pool

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/14/26	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/14/26	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/13/26	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/13/26	3:45 PM	EB	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/13/26	3:45 PM	EB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/13/26	3:45 PM	EB	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)