



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2121

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Club at North Hills*
Address: *700 Lincoln Club Drive*
Pittsburgh, PA 15237

Sample Collection

Date: *7/14/26*
Time: *11:45 AM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: *7/17/26*
Time: *10:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/26	9:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/26	9:50 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/26	4:30 PM	AS	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/14/26	11:45 AM	IS	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	7/14/26	11:45 AM	IS	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/26	11:45 AM	IS	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor