



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2259

**Customer**

Facility Name: Highland Park Club  
  
Address: 151 Lake Dr.  
Pittsburgh, PA 15206

**Sample Collection**

Date: 7/14/26  
Time: 2:30 PM  
Method: Grab

**Sample Final Analysis**

Date: 7/17/26  
Time: 9:30 AM  
Analyst: AS

Matrix: Recreational Water

Source Type: Shallow End

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 7/15/26              | 9:00 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 7/15/26              | 9:00 AM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 7/14/26              | 4:00 PM | AS      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 7/14/26   | 2:30 PM | WB      | DPD    |
| Chlorine:      | 2.0 mg/l | 1.0 - 5.0 mg/l  | 7/14/26   | 2:30 PM | WB      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 7/14/26   | 2:30 PM | WB      | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)