



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 200

Customer

Facility Name: L.A. Fitness Bridgeville

Address: 1155 Washington Pike
Bridgeville, PA 15017

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 1/0/00

Time: 9:10 AM

Method: Grab

Sample Final Analysis

Date: 7/16/26

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/14/26	9:00 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/14/26	9:00 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	7/13/26	4:25 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/13/26	9:10 AM	JB	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/13/26	9:10 AM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/13/26	9:10 AM	JB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor