



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 309

Customer

Facility Name: University Prep Middle School

Address: 3117 Centre Ave.
Pittsburgh, PA 15219

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 7/15/26

Time: 1:07 PM

Method: Grab

Sample Final Analysis

Date: 7/18/26

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	7/16/26	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	A	7/16/26	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	A	7/15/26	4:27 PM	MH	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.2 SU	C	7/15/26	1:07 PM	SL	DPD
Chlorine:	0.5 mg/l	E	7/15/26	1:07 PM	SL	DPD
Turbidity:	1 NTU	A	7/15/26	1:07 PM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)