



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-1

Lab# 060

Customer

Facility Name: *Comfort Inn*
Address: *699 Rodi Rd.*
Pittsburgh, PA 15235

Sample Collection

Date: *9/22/26*
Time: *9:50 AM*
Method: *Grab*

Sample Final Analysis

Date: *9/25/26*
Time: *9:00 AM*
Analyst: *JC*

Matrix: *Recreational Water*
Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/23/26	8:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/23/26	8:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	9/22/26	3:30 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	9/22/26	9:50 AM	SH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/22/26	9:50 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/22/26	9:50 AM	SH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)