



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 125

Customer

Facility Name: Hampton Inn
Address: 475 Johnson Rd.
Washington, PA 15301

Sample Collection

Date: 9/24/26
Time: 12:35 PM
Method: Grab

Matrix: Recreational Water
Source Type: Spa

Sample Final Analysis

Date: 9/26/26
Time: 5:30 PM
Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/24/26	5:10 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/24/26	5:10 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/24/26	5:00 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	9/24/26	5:10 PM	SL	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	9/24/26	12:35 PM	EG	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	9/24/26	12:35 PM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/24/26	12:35 PM	EG	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)