



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 381

Customer

Facility Name: PPG Paints Arena
Address: 1001 Fifth Ave
Pittsburgh, PA 15219

Matrix: Recreational Water

Source Type: Cold Plunge

Sample Collection

Date: 9/21/26
Time: 12:55 PM
Method: Grab

Sample Final Analysis

Date: 9/24/26
Time: 9:00 AM
Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/22/26	8:55 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/22/26	8:55 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	9/21/26	4:40 PM	MH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	9/21/26	12:55 PM	SD	DPD
Chlorine:	7.4 mg/l	1.0 - 5.0 mg/l	9/21/26	12:55 PM	SD	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/21/26	12:55 PM	SD	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor