



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 256

Customer

Facility Name: Plum Boro High School

Address: 900 Elicker Rd.
Pittsburgh, PA 15239

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 9/23/26

Time: 3:30 PM

Method: Grab

Sample Final Analysis

Date: 9/26/26

Time: 10:30 AM

Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/24/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/24/26	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/23/26	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/23/26	3:30 PM	MH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/23/26	3:30 PM	MH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/23/26	3:30 PM	MH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor