



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-2

Lab# 281

Customer

Facility Name: South Fayette High School

Address: 3640 Old Oakdale Rd.
MC Donald, PA 15057

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 9/22/26

Time: 10:43 AM

Method: Grab

Sample Final Analysis

Date: 9/25/26

Time: 9:00 AM

Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/23/26	8:55 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/23/26	8:55 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	9/22/26	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	9/22/26	10:43 AM	MH	DPD
Chlorine:	7.6 mg/l	1.0 - 5.0 mg/l	9/22/26	10:43 AM	MH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/22/26	10:43 AM	MH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)