



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 503

Customer

Facility Name: University of Pgh Rec and Wellness

Address: 3719 Terrace St,
Pittsburgh, PA 15213

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 9/22/26

Time: 10:48 AM

Method: Grab

Sample Final Analysis

Date: 9/25/26

Time: 9:00 AM

Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/23/26 8:55 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/23/26 8:55 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	9/22/26 4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/22/26 10:48 AM	JT	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/22/26 10:48 AM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/22/26 10:48 AM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor
Andre Smith, Lead Supervisor