



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 360

Customer

Facility Name: YMCA - Mon-Valley
Address: 101 Taylor Run Road
Monongahela, PA 15063

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 9/21/26
Time: 2:50 PM
Method: Grab

Sample Final Analysis

Date: 9/24/26
Time: 10:00 AM
Analyst: JC

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	9/22/26 9:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/22/26 9:30 AM	JC	SM 9222B
Standard plate count:	570/ml	200/ml	9/21/26 5:30 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	9/22/26 9:50 AM	AH	SM 9230C
---------------------	----------	----------	-----------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.0 SU	7.2 - 7.8 SU	9/21/26 2:50 PM	SH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	9/21/26 2:50 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/21/26 2:50 PM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor