



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Pace

Lab# 513

Customer

Facility Name: Pace Analytical
Address: 1803 Philadelphia St.
Indiana, PA 15701

Sample Collection

Date: 9/23/26
Time: 10:26 AM
Method: Grab

Sample Final Analysis

Date: 9/26/26
Time: 10:30 AM
Analyst: JC

Matrix: Recreational Water
Source Type: Hot 2

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/24/26	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/24/26	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	9/23/26	4:20 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	9/24/26	10:00 AM	JC	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	6.5 SU	7.2 - 7.8 SU	9/23/26	10:26 AM	TS	DPD
Chlorine:	N/A	1.0 - 5.0 mg/l	9/23/26	10:26 AM	TS	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/23/26	10:26 AM	TS	Visual

Sample comments

Andre Smith, Lead Supervisor