



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 003

Customer

Facility Name: *Allderdice H.S.*

Address: *2409 Shady Ave.*
Pittsburgh, PA 15217

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *9/23/26*
Time: *11:55 AM*
Method: *Grab*

Sample Final Analysis

Date: *9/26/26*
Time: *10:30 AM*
Analyst: *JC*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	9/24/26	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	A	9/24/26	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	A	9/23/26	4:20 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	9/23/26	11:55 AM	JT	DPD
Chlorine:	3.0 mg/l	A	9/23/26	11:55 AM	JT	DPD
Turbidity:	1 NTU	A	9/23/26	11:55 AM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor