



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 045

Customer

Facility Name: Carrick High School
Address: 125 Parkfield St.
Pittsburgh, PA 15210

Matrix: Recreational Water
Source Type: Pool Deep

Sample Collection

Date: 9/23/26
Time: 9:58 AM
Method: Grab

Sample Final Analysis

Date: 9/26/26
Time: 10:30 AM
Analyst: JC

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	9/24/26	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	A	9/24/26	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	A	9/23/26	4:20 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.8 SU	C	9/23/26	9:58 AM	JT	DPD
Chlorine:	2.0 mg/l	B	9/23/26	9:58 AM	JT	DPD
Turbidity:	1 NTU	A	9/23/26	9:58 AM	JT	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)