



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665

Lab ID No. 02-04041

E - 12

Lab# 060

Laboratory Analysis Report

Customer

Facility Name: Comfort Inn
Address: 699 Rodi Road
Pittsburgh, PA 15235

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 9/2/26
Time: 11:45 AM
Method: Grab

Sample Final Analysis

Date: 9/5/26
Time: 12:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/3/26	12:00 PM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/3/26	12:00 PM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	9/2/26	5:19 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	9/2/26	11:45 AM	JT	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/2/26	11:45 AM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/2/26	11:45 AM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor