



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 468

Customer

Facility Name: *Holiday Inn Express*

Address: *3936 Monroeville Blvd.*
Monroeville, PA 15146

Sample Collection

Date: *9/2/26*
Time: *1:58 PM*
Method: *Grab*

Sample Final Analysis

Date: *9/5/26*
Time: *12:30 PM*
Analyst: *AS*

Matrix: *Recreational Water*

Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/3/26	12:00 PM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/3/26	12:00 PM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	9/2/26	5:19 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	9/2/26	1:58 PM	JT	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	9/2/26	1:58 PM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/2/26	1:58 PM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor