



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-12

Lab# 2290

Customer

Facility Name: *Ingomar Swim Club*
Address: *1512 Ingomar Heights Rd.*
Pittsburgh, PA 15237

Sample Collection

Date: *9/3/26*
Time: *3:10 PM*
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: *9/5/26*
Time: *5:30 PM*
Analyst: *AS*

Source Type: *Baby Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/3/26	5:00 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/3/26	5:00 PM	AS	SM 9222B
Standard plate count:	150/ml	200/ml	9/3/26	4:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/3/26	3:10 PM	EG	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	9/3/26	3:10 PM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/3/26	3:10 PM	EG	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)