



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 221

Customer

Facility Name: Masonic Village
Address: 1000 Masonic Dr.
Sewickley, PA 15143

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 8/31/26
Time: 2:47 PM
Method: Grab

Sample Final Analysis

Date: 9/3/26
Time: 12:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/1/26 12:00 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/1/26 12:00 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/31/26 6:05 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	1/100mls	2/100mls	9/1/26 12:50 PM	AS	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/31/26 2:47 PM	MH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/31/26 2:47 PM	MH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/31/26 2:47 PM	MH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)