



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2120

Customer

Facility Name: Club at Nevillewood
Address: 1000 Nevillewood Drive
Presto, PA 15142

Matrix: Recreational Water

Source Type: Small Pool

Sample Collection

Date: 8/31/26
Time: 11:05 AM
Method: Grab

Sample Final Analysis

Date: 9/3/26
Time: 1:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/1/26	12:30 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/1/26	12:30 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/31/26	6:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/31/26	11:05 AM	AS	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/31/26	11:05 AM	AS	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/31/26	11:05 AM	AS	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor