



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2480

Customer

Facility Name: Sewickley Community
Address: 15 Chadwick Street
Sewickley, PA 15143

Sample Collection

Date: 9/3/26
Time: 9:32 AM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 9/5/26
Time: 5:30 PM
Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/3/26	5:00 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/3/26	5:00 PM	AS	SM 9222B
Standard plate count:	570/ml	200/ml	9/3/26	4:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	9/3/26	9:32 AM	SL	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	9/3/26	9:32 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/3/26	9:32 AM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)