



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 289

Customer

Facility Name: Springhill Suites
Address: 122 Daugherty Dr.
Monroeville, PA 15146

Sample Collection

Date: 9/2/26
Time: 9:20 AM
Method: Grab

Sample Final Analysis

Date: 9/5/26
Time: 10:00 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/3/26	9:30 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/3/26	9:30 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	9/2/26	4:34 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/2/26	9:20 AM	JC	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	9/2/26	9:20 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/2/26	9:20 AM	JC	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)