



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-13

Lab# 2435

Customer

Facility Name: Trellis North Fayette
Address: 1500 Park Lane Drive
Pittsburgh, PA 15275

Sample Collection

Date: 9/1/26
Time: 10:54 AM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 9/4/26
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/2/26	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/2/26	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	9/1/26	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	9/1/26	10:54 AM	AMH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	9/1/26	10:54 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/1/26	10:54 AM	AMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)