



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 300

Customer

Facility Name: *Trinity Middle School*
Address: *50 Scenic Dr.*
Washington, PA 15301

Sample Collection

Date: *8/31/26*
Time: *8:00 AM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: *9/3/26*
Time: *11:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/1/26	10:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/1/26	10:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/31/26	4:12 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/31/26	8:00 AM	JM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/31/26	8:00 AM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/31/26	8:00 AM	JM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor