



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 349

Customer

Facility Name: Courtyard University Center

Address: 100 Lytton Ave.
Pittsburgh, PA 15213

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 9/1/26

Time: 9:00 AM

Method: Grab

Sample Final Analysis

Date: 9/4/26

Time: 11:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/2/26	10:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/2/26	10:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	9/1/26	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/1/26	9:00 AM	JT	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/1/26	9:00 AM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/1/26	9:00 AM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor