



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 2719

Customer

Facility Name: Meeder Flats
Address: 1000 Strand Road
Cranberry, PA 16066

Sample Collection

Date: 9/2/26
Time: 2:15 PM
Method: Grab

Sample Final Analysis

Date: 9/5/26
Time: 11:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	9/3/26	10:30 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/3/26	10:30 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	9/2/26	4:49 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	9/3/26	12:40 PM	MH	SM 9230C
---------------------	----------	----------	--------	----------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	8.0 SU	7.2 - 7.8 SU	9/2/26	2:15 PM	EG	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	9/2/26	2:15 PM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/2/26	2:15 PM	EG	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)