



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2607

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Yards @ 3 Crossings*
Address: *2645 Railroad St.*
 Pittsburgh, PA 15222

Sample Collection

Date: 9/1/26
Time: 2:15 PM
Method: Grab

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: 9/4/26
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/2/26	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/2/26	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	9/1/26	5:00 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/1/26	2:15 PM	MB	DPD
Chlorine:	1.5 mg/l	1.0 - 5.0 mg/l	9/1/26	2:15 PM	MB	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/1/26	2:15 PM	MB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor