



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2105

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Christopher Wren Apt.*
Address: *501 Christopher Wren Dr.*
Wexford, PA 15090

Sample Collection

Date: *9/2/26*
Time: *2:28 PM*
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: *9/5/26*
Time: *11:30 AM*
Analyst: *AS*

Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/3/26 11:00 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/3/26 11:00 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	9/2/26 5:09 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/2/26 2:28 PM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	9/2/26 2:28 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/2/26 2:28 PM	MM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)