



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2007

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Adams Pointe
Address: 1000 Adams Pointe Blvd.
Mars, PA 16046

Date: 9/1/26
Time: 4:15 PM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Central Pool

Date: 9/4/26
Time: 12:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/2/26	12:00 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/2/26	12:00 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	9/1/26	6:00 PM	AS	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/1/26	4:15 PM	EG	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	9/1/26	4:15 PM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/1/26	4:15 PM	EG	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor