



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2172

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Edgeworth Club

Date: 9/3/26

Address: 511 East Drive
Sewickley, PA 15143

Time: 9:41 AM

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 9/5/26

Source Type: Pool

Time: 5:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/3/26	5:00 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/3/26	5:00 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	9/3/26	4:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	9/3/26	9:41 AM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	9/3/26	9:41 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/3/26	9:41 AM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)