



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2733

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Fox Plan

Date: 9/2/26

Time: 8:15 AM

Address: 105 Fox Plan Rd.
Monroeville, PA 15146

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 9/5/26

Time: 10:00 AM

Source Type: Pool

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/3/26	9:30 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/3/26	9:30 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	9/2/26	4:34 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	9/2/26	8:15 AM	JC	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	9/2/26	8:15 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/2/26	8:15 AM	JC	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)