



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2681

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Georgetown Commons*
Address: *400 Williamsburg Lane*
Export, PA 15632

Sample Collection

Date: 9/2/26
Time: 10:50 AM
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: 9/5/26
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/3/26	9:30 AM	MH	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/3/26	9:30 AM	MH	SM 9222B
Standard plate count:	0/ml	200/ml	9/2/26	4:34 PM	AH	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	9/2/26	10:50 AM	JC	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/2/26	10:50 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/2/26	10:50 AM	JC	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)