



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2669

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Lincoln House*

Address: *245 Lincoln Ave.*
 Pittsburgh, PA 15202

Sample Collection

Date: *9/3/26*
Time: *11:00 AM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Final Analysis

Date: *9/5/26*
Time: *5:30 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/3/26 5:00 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/3/26 5:00 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	9/3/26 4:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	9/3/26 11:00 AM	EG	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/3/26 11:00 AM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/3/26 11:00 AM	EG	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor