



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

S-15

Lab# 2665

Laboratory Analysis Report

Customer

Facility Name: *Georgetown Estates*

Address: *Old Farm Rd.*
Lawrence, PA 15055

Matrix: *Recreational Water*

Source Type: *Large Pool*

Sample Collection

Date: *9/1/26*

Time: *8:00 AM*

Method: *Grab*

Sample Final Analysis

Date: *9/4/26*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/2/26	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/2/26	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	9/1/26	2:46 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/1/26	8:00 AM	JM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/1/26	8:00 AM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/1/26	8:00 AM	JM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)