



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 269

Customer

Facility Name: Science and Technology Academy

Address: 107 Thackeray St.
Pittsburgh, PA 15213

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 8/31/26

Time: 12:10 PM

Method: Grab

Sample Final Analysis

Date: 9/3/26

Time: 11:00 AM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	A	9/1/26 10:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	A	9/1/26 10:30 AM	AS	SM 9222B
Standard plate count:	0/ml	A	8/31/26 4:12 PM	AH	SM 9215B

Field Analysis	Results	Rating	Date/Time	Analyst	Method
pH:	7.2 SU	C	8/31/26 12:10 PM	JT	DPD
Chlorine:	3.0 mg/l	A	8/31/26 12:10 PM	JT	DPD
Turbidity:	1 NTU	A	8/31/26 12:10 PM	JT	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)