



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**PPS**

**Lab# 045**

**Customer**

**Facility Name:** Carrick High School  
**Address:** 125 Parkfield St.  
Pittsburgh, PA 15210

**Matrix:** Recreational Water  
**Source Type:** Pool Deep

**Sample Collection**

**Date:** 8/31/26  
**Time:** 9:48 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 9/3/26  
**Time:** 11:00 AM  
**Analyst:** AS

| Accredited Analysis   | Results  | Rating | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|--------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | A      | 9/1/26               | 10:30 AM | AS      | SM 9222G |
| Total coliforms:      | 0/100mls | A      | 9/1/26               | 10:30 AM | AS      | SM 9222B |
| Standard plate count: | 0/ml     | A      | 8/31/26              | 3:44 PM  | AH      | SM 9215B |

| Field Analysis | Results  | Rating | Date/Time |         | Analyst | Method |
|----------------|----------|--------|-----------|---------|---------|--------|
| pH:            | 7.8 SU   | C      | 8/31/26   | 9:48 AM | JT      | DPD    |
| Chlorine:      | 3.0 mg/l | A      | 8/31/26   | 9:48 AM | JT      | DPD    |
| Turbidity:     | 1 NTU    | A      | 8/31/26   | 9:48 AM | JT      | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)